

**FUGRO TECHNICAL SERVICES LIMITED**

Fugro Development Centre,  
5 Lok Yi Street, Tai Lam,  
Tuen Mun, N.T.,  
Hong Kong.

Tel : +852 2450 8233  
Fax : +852 2450 6138  
E-mail : matlab@fugro.com.hk  
Website : www.materialab.com.hk



Report No. : 134290CH132487A



**Test Report on Chemical Analysis of Palmeco Master Board**

**Information Supplied by Client**

Client : PALMECO TECH LTD.  
Client's address : Room 903, 9/F, Champion Building,  
287-291 Des Voeux Road Central, Sheung Wan, Hong Kong  
Project : Palmeco Master Board  
Sample description : One sample of board – Palm Fibre with Magnesia Cement  
Product type : PalmEco Master  
Tests required : Water-soluble chloride content

**Laboratory Information**


Laboratory sample ID. : CH132487/1  
Date of receipt of sample : 02/12/2013  
Date test commenced : 02/12/2013  
Date test completed : 16/12/2013  
Test methods used : Ref. ASTM C1218/C 1218M - 99

**Result :**

Water-soluble chloride content (as Cl<sup>-</sup>) by mass of sample ..... 3.94 %

Remark : This report is to supersede our former report #134290CH132487.

Supervised by :           H.Y. Chan          

Certified by   
Approved Signatory: AU Kwok Man, Bruce  
Assistant Manager - Chemical Laboratory

Date :           24/12/2013          

\*\* End of Report \*\*

*Note : This report refers only to the sample(s) tested.*